



Section A-A



Section B-B




after refractory lining works,
casting opening will be
welded gas tight by pressure
part Erection Company


Nozzle to be wrapped
with ceramic fibre paper
3mm thick

Pressure + Temperature measuring points

Level	Right Side	No.	Original-dwg-no.
+53,470	1x	01 HBK 40 CP 001	MTZ/01/B/HAD40/00215/0439
+53,470	1x	01 HBK 40 CP 002	MTZ/01/B/HAD40/00215/0439
+53,470	1x	01 HBK 40 CP 003	MTZ/01/B/HAD40/00215/0439
+53,470	1x	01 HBK 40 CP 004	MTZ/01/B/HAD40/00215/0439
+53,470	1x	01 HBK 40 CP 005	MTZ/01/B/HAD40/00215/0439



Refractory Concrete MAT PLUS MC 50



Ceramic fibre 1250°C

RELEASED FOR CONSTRUCTION 22.07.08
Drawing valid for Unit 1 and Unit 2

Rev.	Revision	Date	Created by	Checked by	Approved by	Description	Status
2	22.07.2008	Hilgenfeldt	Buchholz	Blachetta		Info of valid / title block	Released
1	16.06.2008	Hilgenfeldt	Buchholz	Blachetta		Released for Construction	Released
0	02.01.2008	Bertling	Vake	Blachetta		First Issue	Released

Project (Проект)

Maritza East I Power Station

Company (Възложителя)

Space for stamp of Municipality of Galabovo
Място за печат на Община Гълъбово

Space for further stamps
Място за допълнителни печати

Area for Stamp of EQE Control DDD (ICS)
Място за печат EQE ControlDDD (Незав. надзор)

ASpace for stamp of authorized Bulgarian Designer
Място за печат на лицензиран български проектант

Main Contractor / Главен изпълнител

Power Generation AG
Power Boiler GmbH

Partner of Main Contractor / Партньор на главния изпълнител

Resp. dept. / Отговорен отдел	Created by / Изготвил	Checked by / Проверил	Approved by / Одобрил	Format / Формат
	Bertling	Vake	Blachetta	A2
Scale / Машаб			Class. no. (e.g. KKS) Класирик ?	
1:10			for Company Review & Approval: За одобрение от Възложителя: Yes	
Derived from / Произтича от	Replaces / Заменя	Doc. Type Тип на документа	Document Status Статус на документа	Sub Site No. / Подобект ?
		ES	RFC	
Logo of Legal Owner Официален собственик		Sub Contractors Doc Number / ? на документа на подизпълнителя		Consortium Partner Document Code Код на документа на партньора от консорциума 1.48120_00761_0018
		Title, Subtitle / Заглавие, подзаглавие		Project Doc. Number / ? на проектния документ
		Refractory Lining MEASURING POINT		MTZ/12/B/-----00761/ES/018
		Rev. Ред	Date Дата	Lang. Език
		2	02/01/2008	EN
		Sheet Страница	1/1	