

6

5

4

3

2

1

H

G

F

E

C

B

A

NOTES

- 1-DUAL RANGE FLOW MEASUREMENT
- 2-VENT VALVE LOCATED ON VERTICAL PIPE AND ABOVE FWT LIQUID LEVEL
- 3-ONLY ONE PERFORMANCE FLOWMETER FOR THE SIX PUMPS OF BOTH UNITS
- 4- HORIZONTAL FILTER

SEE DETAIL A

FEEDWATER TANK

DETAIL A

LEGEND

SCOPE OF SUPPLY

- B : STEAM GENERATOR
- C : CUSTOMER
- M1 : TURBINE HALL
- M2 : B.O.P.
- S : STEAM TURBINE SET SUPPLIER
- W : CIVIL WORKS CONTRACTOR

GENERAL NOTES

- 1- FUNCTION CODES ARE PRECEDED BY 09 AS UNIT IDENTIFIER FOR COMMON
- 01 FOR UNIT 1
- 02 FOR UNIT 2

02				ОДОБРЕНА ЗА ИЗПОЛЗВАНЕ
01				ОДОБРЕНА ЗА ИЗПОЛЗВАНЕ
00	08.12.2014	N.Armyanov	I.Tzonev	ОДОБРЕНА ЗА ИЗПОЛЗВАНЕ
PEB/REV	Дата	Начертава	Проверка	Имененос
		Drawn by	Checked by	Details of Revision
Design Contract No:		ЕИ И ЕС ЗС ТЕЛМАРИЦА ИЗТОК I		
		AES 3C MARITZA EAST I TRP		
DATA DATE	08.12.2014	ИМЕ НА ПРОЕКТА / PROJECT NAME		ИМЕ НА ПРОЕКТА
НАЧЕРТАН DRAWN BY	N.Armyanov	ПОДПИС / SIGNATURE		PROJECT NAME
ПРОБЕРИТ CHECKED BY	I.Tzonev	ЗАГЛАВИЕ НА ЧЕРТЕЖА / TITLE OF THE DRAWING		
ОДОБРЕН RELEASED		Piping and Instrumentation Diagram Feedwater Pump		
ЗАМЕЧА REPLACES	MTZ/12 M/LAC-----/FD/001	ИЛИ НА ИСТОЧНИК		ВЕРСИОНА: 01
SCALE	1:1mm	ДОКУМЕНТА		ЛИСТ №: 01
FORMAT	A1	KKS НА ЧЕРТЕЖАТА		РЕВ: 00
		SYSTEM KKS CODE		
		LAC		
		THIRD ANGLE PROJECTION		
		PART:		